



Certificate No: 19/1354-8 A2683

Client: Gallagher Limited
James Corbett Road
Salford
Greater Manchester
M50 1DE

Unit 5, Draycott Mills
Off Market Street
Draycott
Derby
DE72 3NB
Tel: 01332 873168
Fax: 01332 875335
e-mail: info@mattestlabs.co.uk

Classification for Constituents of Coarse Recycled Aggregate

BS EN 933-11 :2009 & SHW 710

We refer to a non flowable SMR sampled from James Corbett Road, Salford, Manchester, M50 1DE
The sample(s) was tested on 01/06/2020 to 07/06/2020.

Project & Sample Details

Project:	Non Flowable SMR - Routine 6 Monthly testing suite	Sample Cert. Received:	YES
Source:	James Corbett Road, Salford, Manchester, M50 1DE	Sample Location:	STOCKPILE
Ticket No:	N/A	Sample Ref:	DU1
Material & Designation (d/d):	NON FLOWABLE SMR	Date Sampled:	18/03/2020
Specification:	N/A	Date Received:	18/03/2020

Test Result

Description	Found (cm ³ /kg)	Specification (cm ³ /kg)
Floating particles	0	-

Description	Proportion (%)	Specification (%)
Concrete, concrete products, mortar, concrete masonry units	0.8	-
Unbound aggregate, natural stone, hydraulically bound aggregate	60	-
Clay Masonry units (i.e. bricks and tiles), Calcium silicate masonry units, Aerated non-floating concrete	0.9	-
Bituminous materials	38	-
Glass	0.3	-
Other – Cohesive (i.e. clay and soil), Miscellaneous: metals (ferrous and non-ferrous), non-floating wood, plastic, rubber, gypsum plaster	0	-
	100	

COMMENTS:

Authorised Signature:

W J Larner

Name:

Bill Larner

Position

Technical Director

Date:

08/06/2020