

**LABORATORY TEST CERTIFICATE
MATERIALS LABORATORY**

Certificate No: 19/1354-30

To : Rachel Moore

Client : Gallagher Limited
James Corbett Road
Salford
Greater Manchester
M50 1DE

Date: 30/09/2020

Dear Sirs,

FIELD & LABORATORY TESTING

Introduction

We refer to a sample taken from site on the 16th September 2020.

Tested By : MATtest Laboratories Ltd

Sample Reference : A2829

Description : NFSMR 50/50 Mix

Date Sampled : 16th September 2020

Date Tested : 18th - 28th September 2020

Source : Not stated

Weather : N/A

Test Results;

Please see attached

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation
This report should not be reproduced except in full without the written approval of the laboratory
All remaining samples for this project will be disposed of 28 days after issue of this test certificate
When a statement of conformity is requested for a test result against limits set out in a standard or specification (e.g. BS EN ISO, SHW) that already considers measurement uncertainty, MATtest Laboratories decision rule is to follow conformity requirements of the applicable standard or specification.
Results reported only relate to the items tested/ received.

Remarks;

Approved for Issue:



Position:

Technical Manager

Issuing Office:



Head Office & Central

Unit 5 Draycott Mills, Off Market Street, Draycott, Derby, DE72 3NB



North West

Unit 15 Park Court, Sherdley Business Park, St. Helens, Merseyside, WA9 5GZ

Tel: 03333 202521 Web: www.mattestlaboratories.co.uk



7806

Certificate No: 19/1354-30 A2829
Client: Gallagher Limited
James Corbett Road
Salford
Greater Manchester
M50 1DE

Unit 5, Draycott Mills
Off Market Street
Draycott
Derby
DE72 3NB
Tel: 01332 873168
Fax: 01332 875335
e-mail: info@mattestlabs.co.uk

Dear Sirs,

SIEVE ANALYSIS - BS EN 933 : Part 1 : 2012


We refer to a bulk sample supplied from site and delivered to our laboratory on 16/09/2020.
The sample was tested between the 18/09/2020 - 28/09/2020.

Project & Sample Details

Project: Weekly Sampling & Testing	Sample Ref: A2829	Material: NFSMR 50/50 Mix
Source: James Corbett Road	Specification: -	Date Sampled: 16/09/2020 Sampled by: D. Upton
Ticket No: N/A	Sample Cert. Received: Yes	Date Received: 16/09/2020
Sample Location: Not stated	Lane: N/A	Layer: N/A

Test Result

Sieve Size (mm)	%Passing	Specification	
		Spec.Min	Spec.Max
40 mm	100		
31.5 mm	95		
28 mm	93		
20 mm	81		
16 mm	71		
14 mm	67		
10 mm	54		
8 mm	48		
6.3 mm	43		
5 mm	38		
4 mm	34		
3.35 mm	32		
2 mm	27		
1 mm	21		
0.5 mm	15		
0.25 mm	8		
0.125 mm	4		
0.063 mm	1.1		



WATER CONTENT: 7.9%

COMMENTS: Negative PAK test

J. Pullar

Authorised Signature: J. Pullar, Technical Manager

Dated: 15/09/2020



LABORATORY TEST CERTIFICATE



Certificate No: 19/1354-30 A2829
Client: Gallagher Limited
James Corbett Road
Salford
Greater Manchester
M50 1DE

Dear Sirs,

Determination of Moisture Content - BS 1377-2:1990 Clause 3
Determination of Plastic Limit - BS 1377-2:1990 Clause 5.3
Determination of Liquid Limit - BS 1377-2:1990 Clause 4.3
Determination of Plasticity Index - BS 1377-2:1990 Clause 5.4

Introduction

We refer to a sample taken from site and delivered to our laboratory on 16/09/2020.

Material & Source

Sampled by : D. Upton
Sample Reference : A2829
Location : Site
Date Sampled : 16/09/2020
Source : Ex site
Date Tested : 18/09/2020 - 28/09/2020
Sampling Certificate : Yes

Test Results:	<u>A2829</u>
Moisture Content :	N/A
Liquid Limit :	N/A
Plastic Limit :	Non plastic
Plasticity Index :	N/A
% retained on 425 micron	N/A
Description / Designation	NFSMR 50/50 Mix

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation
This report should not be reproduced except in full without the written approval of the laboratory
All remaining samples for this project will be disposed of 14 days after issue of this test certificate

Remarks;

Approved for Issue Date 30/09/2020

J. Pullar
Technical Manager

Unit 5, Draycott Mills
Off Market Street
Draycott
Derby
DE72 3NB
Tel: 01332 873168
Fax: 01332 875335
e-mail: info@mattestlabs.co.uk